

F. Alleys

1. Alleys shall be required to serve lots used for commercial and industrial purposes except that this requirement may be waived where other definite and assured provision is made for service access. Alleys shall not be provided in residential subdivisions unless necessitated by unusual circumstances.
2. The width of an alley shall be at least twenty (20) feet.
3. Dead-end alleys shall be avoided where possible, but if unavoidable, shall be provided with adequate turn-around facilities at the dead end as may be required by the Planning Board.

G. Permits For Connection To State Roads

An approved permit is required for connection to any existing state system road. This permit is required prior to any construction on the street or road. The application is available at the office of the District Engineer of the Division of Highways.

H. Offsets To Utility Poles

Poles for overhead utilities should be located clear of roadway shoulders, preferably a minimum of at least 30 feet from the edge of pavement. On streets with curb and gutter, utility poles shall be set back a minimum distance of 6 feet from the face of curb.

I. Wheelchair Ramps

All street curbs being constructed or reconstructed for maintenance purposes, traffic operations, repairs, correction of utilities, or altered for any reason, shall provide wheelchair ramps for the physically handicapped at intersections where both curb and gutter and sidewalks are provided and at other major points of pedestrian flow.

J. Horizontal Width on Bridge Deck

1. The clear roadway widths for new and reconstructed bridges serving 2 lane, 2 way traffic should be as follows:
 - a. Shoulder section approach
 - i. Under 800 ADT design year
Minimum 28 feet width face to face of parapets of rails or pavement width plus 10 feet, whichever is greater.
 - ii. 800 - 2000 ADT design year
Minimum 34 feet width face to face of parapets of rails or pavement width plus 12 feet, whichever is